



ADDENDUM NO. 1

IFB #26-012B UMass Lift Replacement

May 29, 2026

This Addendum is being issued to clarify the IFB documents and shall supersede and supplement all portions of previously issued IFB documents with which it conflicts.

There were seven attendees at the pre-bid conference scheduled for May 27, 2026 at 10:00 AM EST.

Please see attached Pre-Bid Meeting signing sheet.

All other requirements of the IFB shall remain in full force and effect.

Pioneer Valley Transit Authority

2808 Main Street, Springfield, MA 01107 Phone: 413-732-6248 Fax: 413-737-2954

www.pvta.com



375 Essay Road, Suite 200, Williamsville, New York 14221
P 716.688.0766 F 716.625.6825

Project	<u>Pioneer Valley Transit Authority</u>	Addendum No.	<u>01</u>
	<u>UMASS Lift Replacement</u>	Contract	<u>26-012B</u>
Wendel Project No.	<u>448715</u>	Date	<u>5/29/26</u>

ARTICLE -	<u>1</u>	DRAWING NO.	<u>N/A</u>
		SPEC SECTION	<u>N/A</u>

ADDITIONAL INFORMATION: See attached pre-bid meeting sign-in sheet.

ARTICLE -	<u>2</u>	DRAWING NO.	<u>N/A</u>
		SPEC SECTION	<u>007100</u>

QUESTION: Is the \$20M umbrella policy requirement required. This amount seems extraordinarily high for a project of this size. Please confirm.

RESPONSE: The insurance limits for the project as defined in the Supplementary Conditions of the Contract included in the IFB documents, Specification 007100 shall be reduced as follows:

11.1.4.3 Commercial Umbrella – GC Umbrella limits of at least \$20,000,000 shall be reduced to at least \$5,000,000.

ARTICLE -	<u>3</u>	DRAWING NO.	
		SPEC SECTION	<u>015000</u>

CLARIFICATION: A question was asked at the pre-bid meeting relating to the temporary partition. See Temporary Facilities and Controls 015000 3.4 G for requirements and location.

ARTICLE -	<u>4</u>	DRAWING NO.	<u>2/S101, 9/S101</u>
		SPEC SECTION	<u>N/A</u>

CLARIFICATION: G-clips for removable bar grating shall be omitted over the center trench and at the 2'-0" square removable panel at the pit. Refer to Details 2/S101 and 9/S101.

Pre-Bid Meeting Sign-In Sheet



Project No.: 448715

Date: 5/27/26

Project Name: PVT A UMass Lift Replacement

Meeting Location: UMass Transit Facility - 185 Holdsworth Way

Company Name	Name of Attendee (Please Print)	Phone Number	Email Address
1 PowerAmerica	John Campbell	8004471226	John@powerwasher sales.com
2 Palmer Electric	Chad Tatro	413-800-5227	chad.palmer@electric.com
3 Ketter	Leo Ketter	413-324-1437	Leo@ketter.com
4 MJC Welding & Fabrication LLC	Matthew J. Casarolo	413-867-9947	mjcweld@gmail.com
5 ABW, INC.	STEVEN HILL	413-732-3179	STEVE @ BUNDLING & ELECTRS. CO.
6 Grace Vlan	WENDEL		
7 Tom Vincent	UMTB		
8			